



Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

DowAksa USA, LLC
1881 W Oak Parkway
Marietta, GA 30062, United States

Plant Location:

Tucson, AZ, United States

Standards:

NSF/ANSI 61 Section 5

Certificate:

Issued: 12/12/2015
Expires: 12/31/2020

Material/Product:

Carbon Fiber Reinforced Polymers (CFRP)

Contact Temperature:

23 ± 2 °C

Models:

CarbonBond™ 200 Adhesive Putty System (Fast Cure System)

CERTIFICATION WITHDRAWN



Material Characteristics:

Minimum pipe diameter (inches): 108

Maximum pipe surface area/volume ratio (sq in/L): 2.3

Minimum tank size (gallons): 750,000

Maximum tank surface area/volume ratio (sq in/L): 0.63

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): Refer to manufacturer instructions for details

Shortest cure time between coats or layers: 72 hours

Mix ratio: 2:1 (A:B) by Volume

Colors: Clear Red

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): Yes



Product certified to NSF/ANSI 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.