



## Certified Product Listing

**For:**

Drinking Water System Components – Health Effects

**Company:**

DowAksa USA, LLC  
1881 W Oak Parkway  
Marietta, GA 30062, United States

**Plant Location:**

Tucson, AZ, United States

**Standards:**

NSF/ANSI 61 Section 5

**Certificate:**

Issued: 01/14/2016  
Expires: 12/31/2020

**Material/Product:**

Carbon Fiber Reinforced Polymers (CFRP)

**Contact Temperature:**

23 ± 2 °C

**Models:**

CarbonBond™ 200P Adhesive Putty System

**CERTIFICATION WITHDRAWN**



## Material Characteristics:

Minimum pipe diameter (inches): 16

Maximum pipe surface area/volume ratio (sq in/L): 15.3

Minimum tank size (gallons): 20,000

Maximum tank surface area/volume ratio (sq in/L): 2.1

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): Refer to manufacturer instructions for details

Shortest cure time between coats or layers: 72 hours

Mix ratio: 2:1 (A:B) by Volume

Colors: Green

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): Yes



Product certified to NSF/ANSI 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.