



Certified Product Listing

For:

Drinking Water System Components – Health Effects

Company:

DowAksa USA, LLC
1881 W Oak Parkway
Marietta, GA 30062, United States

Plant Location:

Tucson, AZ, United States

Standards:

NSF/ANSI 61 Section 5

Certificate:

Issued: 12/14/2015
Expires: 12/31/2020

Material/Product:

Carbon Fiber Reinforced Polymers (CFRP)

Contact Temperature:

23 ± 2 °C

Models:

CarbonBond™ 300 Saturant Resin System (Slow Cure System)
CFB10T
CFB20T
CFU10T
CFU20T
CFU40T

CERTIFICATION WITHDRAWN



Material Characteristics:

Minimum pipe diameter (inches): 48

Maximum pipe surface area/volume ratio (sq in/L): 5.1

Minimum tank size (gallons): 10,000,000

Maximum tank surface area/volume ratio (sq in/L): 0.26

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): Refer to manufacturer instructions for details

Shortest cure time between coats or layers: 72 hours

Mix ratio: 2:1 (A:B) by Volume

Colors: Translucent Red

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): Yes